Aggregate Sample Report

Material : 10065034 - GRAVILLA TRIT ARENISCA 4.75-12.5 MM (#7)
Supplier : HMOK-MONDONEDO - AGREGADOS MONDOÑEDO
Supplier Ref No. : PLANTA MONDOÑEDO
Source : AGREGADOS MONDONEDO
Grading Specification : PARTICULAR HMOK-G7
Report Text 1 :
Report Text 2 :

Date : 06 Jun 2023
Sample Date From : 01 May 2023
Sample Date To : 31 May 2023
Plant : HMOK MATERIALES

% Passing

Sample Date	Sample ID	3/4"	1/2"	3/8"	No. 4	No. 8	No. 200	FM	SG	Absorp
	Min Pass	100.0	90.0	40.0	0.0	0.0	0.0			
	Max Pass	100.0	100.0	75.0	20.0	10.0	3.5			
5/2/2023	GRAVA 7	100.0	96.3	68.6	5.3	2.7	1.8	6.16		
5/9/2023	GRAVA 7	100.0	98.2	73.4	8.3	3.3	2.0	6.06		
5/16/2023	GRAVA 7	100.0	97.1	69.6	8.3	3.4	1.8	6.10		
5/23/2023	GRAVA 7	100.0	96.7	72.5	6.5	3.4	2.1	6.08		
5/29/2023	GRAVA 7	100.0	97.2	69.7	7.8	3.8	2.1	6.09		

	3/4"	1/2"	3/8"	No. 4	No. 8	No. 200	FM
Count	5	5	5	5	5	5	5
AVG	100.0	97.1	70.8	7.2	3.3	2.0	6.10
STDEV	0.0	0.7	2.1	1.3	0.4	0.1	0.04
Range Min	100.0	96.3	68.6	5.3	2.7	1.8	6.06
Range Max	100.0	98.2	73.4	8.3	3.8	2.1	6.16
COV	0.0	0.7	2.9	18.1	11.9	7.7	0.62


Porcentaje de sedimentos	1.95	%
Humedad de agregados	3.58	%
Módulo de finura	6.0976	
Tamaño nominal agregado	12.5000	
Partículas fracturadas	100.00	%
Indice de aplanamiento	29.06	%
Indice de alargamiento	32.58	%
Microdeval	27.64	%
Partículas fracturadas 2 cara	100.00	%
Desgaste en Máquina de los	29.60	%

Approved By :


Angie Carolina Gil López Certification # :

Aggregate Sample Report


Average Grading



Individual Gradings



Time Line



Approved By :

Angie Carolina Gil López Certification # :