Aggregate Sample Report

Material : 10071148 - ARENA TRIT SP 75ÂµM - 4.75MM
Supplier : HMOK-MONDONEDO - AGREGADOS MONDOÑEDO
Supplier Ref No. : PLANTA MONDOÑEDO
Source : AGREGADOS MONDONEDO
Grading Specification : Arena HMOK MYAV1
Report Text 1 :
Report Text 2 :

Date : 07 Jun 2023
Sample Date From : 01 May 2023
Sample Date To : 31 May 2023
Plant : HMOK MATERIALES


% Passing

Sample Date	Sample ID	3/8"	No. 4	No. 8	No. 16	No. 30	No. 50	No. 100	No. 200	FM	SG	Absorp
	Min Pass	100.0	90.0	60.0	40.0	25.0	15.0	10.0	5.0			
	Max Pass	100.0	100.0	90.0	70.0	60.0	50.0	40.0	17.0			
5/2/2023	ARENA DE TRITURACIÓN	100.0	96.7	69.1	48.5	37.5	30.9	20.6	9.6	2.97		
5/9/2023	ARENA DE TRITURACIÓN	100.0	99.0	82.6	56.5	43.0	34.1	24.9	14.5	2.60		
5/18/2023	ARENA DE TRITURACIÓN	100.0	97.7	74.0	51.4	40.9	35.4	27.4	14.9	2.73		
5/26/2023	ARENA DE TRITURACIÓN	100.0	98.9	74.0	55.5	45.8	40.0	27.1	12.9	2.59		

	3/8"	No. 4	No. 8	No. 16	No. 30	No. 50	No. 100	No. 200	FM
Count	4	4	4	4	4	4	4	4	4
AVG	100.0	98.1	74.9	53.0	41.8	35.1	25.0	13.0	2.72
STDEV	0.0	1.1	5.6	3.7	3.5	3.8	3.1	2.4	0.18
Range Min	100.0	96.7	69.1	48.5	37.5	30.9	20.6	9.6	2.59
Range Max	100.0	99.0	82.6	56.5	45.8	40.0	27.4	14.9	2.97
COV	0.0	1.1	7.5	7.0	8.4	10.8	12.6	18.6	6.50

Porcentaje de sedimentos	12.99	%
Humedad de agregados	3.62	%
Módulo de finura	2.7221	
Límite líquido LL	0.00	%
Limite Plastico	0.00	%

Average Grading




Approved By :


Angie Carolina Gil López Certification # :

Aggregate Sample Report

Individual Gradings



Time Line



Approved By :

Angie Carolina Gil López Certification # :