

©CBI AMERICAS LTD. 2008. ALL RIGHTS RESERVED. CONTAINS CONFIDENTIAL INFORMATION PROPRIETARY TO CB&I, OR ITS AFFILIATES; CLIENTS OR SUPPLIERS AND MAY NOT TO BE USED, REPRODUCED OR DISCLOSED WITHOUT CB&I'S PRIOR WRITTEN PERMISSION.

6"

4"

CERTIFIED BY
(NAME OF MANUFACTURER)

CONTRACTOR

SEE NOTE NO.1

MFR. SERIAL NO.

REGISTRATION NO.

ITEM NO.

DATE BUILT

M.A.W.P. PSI AT DES. TEMP. °F

MAXIMUM ALLOWABLE PSI AT DES. TEMP. °F
EXTERNAL PRESSURE
(NOTE 5)

M.D.M.T. °F AT PSI

SERVICE: _____

P.O. NO. _____

INSPECTED BY _____

HYDROSTATIC TEST PRESSURE _____

NOTES:

- 1. IN THIS AREA THE FABRICATOR IS TO STAMP THE CODE SYMBOL FOLLOWED BY OTHER MARKINGS AS REQUIRED BY CODE.
- 2. ALL THE INFORMATION ABOVE IS MINIMUM REQUIRED. SEE PROJECT SPECIFICATION FOR OTHER INFORMATION.
- 3. MANUFACTURER MAY SUBSTITUTE HIS OWN STANDARD NAME PLATE PROVIDING ALL THE ABOVE INFORMATION AND OTHER INFORMATION AS REQUIRED BY PROJECT SPECIFICATION APPEARS ON IT.
- 4. NAME PLATE MATERIAL TO BE 1/16" THK. STAINLESS STEEL.
- 5. MAXIMUM ALLOWABLE EXTERNAL WORKING PRESSURE IS REQUIRED ONLY WHEN SPECIFIED AS A DESIGN CONDITION.

-	-	-	-	-	-
-	-	-	-	-	-
2	ISSUED FOR DESIGN	MW	MS	SAA	11FEB10
1	ISSUED FOR DESIGN	BJD	SAA	FK	11/13/08
A	ISSUE FOR REVIEW	TAA	IAR	IAR	8/19/08
NO.	REVISION	DRAWN	CK'D	APPD	DATE





Cartagena Refinery
Expansion Project

NAME PLATE

FOR: Refineria de Cartagena

DWG NO: 166000-000-DG-MV09-0072 REV: 2

DRAWN: MLV CK'D: APPD: DATE: SCALE: NTS PROJECT NO: