

Commissioning & Installation / Assembly Service Report

14/02/2026

GOBERNACION DE RISARALDA
GOBERNACION DE RISARALDA - SITE

Our reference: SEP500-005100038135 / WO-13667012
Report prepared by HELIO JAVIER GONZALEZ VARGAS

Customer reference:

Customer contact: Juan Pablo Buitrago

Report approved by Yuly Parada Valle

Schneider Electric
Complejo Industrial Celta Trade Park,, Bodega 105, Km. 7
250027 Funza
CO
3208758891
helio.gonzalez@se.com

GOBERNACION DE RISARALDA
CALLE 19 13-17
000 Pereira
Colombia
3127142084
juan.buitrago@risaralda.gov.co

Life Is On Schneider Electric

Table of content

Executive summary p.3
Final considerations p.3
Execution tools and cybersecurity principle p.6
Test equipment p.6
Security principles for greater Trust p.6

Life Is On Schneider Electric

Executive summary

Final considerations

El cliente recibe la UPS y en compañía de ELATIN realiza retiro de embalaje del transporte encontrando averías en el chasis del equipo y lo vuelve a embalar para entrega a Schneider y cambio de esta UPS.

El día de hoy se realiza nueva inspección con personal de ELATIN que consiste en nuevamente retirar embalaje de empaque de la UPS para la inspeccionar que daños eléctricos, electrónicos y físicos presenta la UPS y así poder realizar el cambio de garantía por otra de la misma referencia.

Al realizar el desembalaje la UPS esta no presenta ningún daño en la parte eléctrica y electrónica, solo presenta un hundimiento en la tapa superior la cual no influye en el funcionamiento de la UPS. Además de esta tapa superior también se evidencia la falta de seguro en la tapa lateral derecha que se debe instalar.

Se reitera, este daño no influye en la parte operativa de la UPS y ya resolviendo el cambio de esta, es posible realizar la instalación sin ningún problema.

ASSY ROOF 19" 900MM VX BLK P/N: 0M-6082C-001

LOCK SIDE PANEL NETSHELTER BLK - RED KEY P/N: 0J-870-5157.

La UPS se vuelve a dejar empacada como se recibe de la transportadora.

MODELO Y SERIE.




Life Is On Schneider Electric


INGRAM MICRO
23/01/2026
MAT.
6128091
P/N
SY40K40F
1
BUNDLE X 3 PALLET 1 DE 3



FRAGILE



















Life Is On Schneider Electric

Execution tools and cybersecurity principle

Test equipment

Following test equipment has been used during the intervention:

Type	Model	Serial number	Next calibration date
Multimeter	Fluke 376 FC		23/03/2026

Security principles for greater Trust

At Schneider Electric, our commitment to Life is On begins with our dedication to building and nurturing Trust with our customers. Incorporating security into every facet of our operations - from design to maintenance - we require all of our Service Representatives operating in customer Digital and Operational environments to be Schneider Electric certified.

The Cyber Badge certification means that Service Representatives have undergone training on secure operation principles consistent with cybersecurity industry-leading standards such as IEC 62443-2-4 and ISO 27001, and possess up-to-date IT equipment and software to carry out their work on a customer site. The goals of the Cyber Badge program are to prevent Service Representatives from becoming threat vectors, ensure they operate in a manner consistent with cybersecurity standards, and provide them with training to help detect and report cybersecurity incidents.