



ISO/IEC 17065:2012
10-CPR-009



SGS COLOMBIA S.A.S.

C&P-F490101

ORDEN No. 4200_31408

CERTIFICADO No. CRS15788

ORDEN CERT. No. CO-CERT200500428-04

CERTIFICADO DE CONFORMIDAD DE PRODUCTO

Acme León Plásticos S.A.S.

Calle 27 No. 7A-01, Funza

Certifica que el producto identificado como **Canaletas Plásticas y Accesorios Para Canaletas**, importados y/o fabricados y comercializados en Colombia por **Acme León Plásticos S.A.S.**, con referencias relacionadas en las siguientes páginas del presente documento, han sido evaluados de conformidad con:

Resolución 90708 del 30 Agosto de 2013 del Ministerio de Minas y Energía - por lo cual se expide el Reglamento Técnico de Instalaciones Eléctricas - RETIE.

Numeral 20.6 CANALIZACIONES

Subnumeral 20.6.2 CANALIZACIONES SUPERFICIALES METÁLICAS Y NO METÁLICAS (CANALETAS)

Estos productos han sido sometidos a toma de muestras, inspección, ejecución de pruebas de laboratorio y evaluación del sistema de gestión de calidad del fabricante de acuerdo con el esquema de certificación 5 de la norma ISO/IEC 17067:2013.

Resultados obtenidos: CONFORME

Autorizado por:

SGS COLOMBIA S.A.S.

Camilo Ramirez

SGS Colombia S.A.S.

Carrera 100 No. 25C-11, Bodega 3

Bogotá D.C., Colombia

Fecha de Emisión: 2020-05-07

Fecha de Vencimiento: 2026-05-07

Versión 2; 2023-03-03

Página 1 de 4



This document cancels and supersedes the last version of this certificate number issued by SGS Colombia S.A.S.

Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to: sgs.servicioalcliente@sgs.com. Via phone No. (+57) 601608282 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/terms-and-conditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023





ISO/IEC 17065:2012
10-CPR-009



SGS COLOMBIA S.A.S.

C&P-F490101

ORDEN No. 4200_31408

CERTIFICADO No. CRS15788

ORDEN CERT. No. CO-CERT200500428-04

CERTIFICADO DE CONFORMIDAD DE PRODUCTO

Acme León Plásticos S.A.S.

Calle 27 No. 7A-01, Funza

Canaletas Plásticas y Accesorios Para Canaletas

Fabricadas por

Acme León Plásticos S.A.S.

Calle 27 No. 7A-01, Funza

Referencia	Material	Espesor (mm)	Dimensiones Externas - Ancho (mm)	Dimensiones Externas - Alto (mm)	Dimensiones Externas - Largo (mm)	Volumen (mm³)	Estándar De Ensayo	Marca
CANALETA 12X7 MICRO ADH	PVC	Base: 0,7 (+/-0,1) Tapa: 0,7 (+/-0,1)	12,3 (+/-0,5)	6,6 (+/-0,5)	2000 (+/-3,0)	49,9 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 12X9 MICRO ADH	PVC	Base: 0,8 (+/-0,2) Tapa: 0,8 (+/-0,2)	12,8 (+/-0,5)	9,0 (+/-0,5)	2000 (+/-3,0)	74,3 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 20X10 CLIP LISA CON Y SIN ADH	PVC	Base: 0,9 (+/-0,2) Tapa: 0,9 (+/-0,2)	20,4 (+/-0,5)	8,8 (+/-0,5)	2000 (+/-3,0)	114,2 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 20X10 BISAGRA CON Y SIN ADH	PVC	Base: 0,7 (+/-0,1) Tapa: 0,6 (+/-0,1)	21,0 (+/-0,5)	10,0 (+/-0,5)	2000 (+/-3,0)	156,7 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 20X20 LISA CON Y SIN ADH	PVC	Base: 0,9 (+/-0,1) Tapa: 0,9 (+/-0,1)	20,2 (+/-0,5)	18,0 (+/-0,5)	2000 (+/-3,0)	234,5 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 22X15 LISA CON Y SIN ADH	PVC	Base: 0,8 (+/-0,1) Tapa: 0,8 (+/-0,1)	23,5 (+/-0,5)	13,2 (+/-0,5)	2000 (+/-3,0)	203,0 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 25X25 LISA CON Y SIN ADH	PVC	Base: 1,1 (+/-0,2) Tapa: 1,0 (+/-0,2)	25,0 (+/-0,6)	21,8 (+/-0,6)	2000 (+/-3,0)	423,7 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 32X12 DIVISION CON Y SIN ADH	PVC	Base: 0,9 (+/-0,1) Tapa: 0,9 (+/-0,1)	30,6 (+/-0,5)	11,4 (+/-0,5)	2000 (+/-3,0)	236,7 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 32X12 LISA CON Y SIN ADH	PVC	Base: 0,9 (+/-0,1) Tapa: 0,9 (+/-0,1)	30,6 (+/-0,5)	11,4 (+/-0,5)	2000 (+/-3,0)	247,7 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 40X25 DIVISION CON Y SIN ADH	PVC	Base: 1,1 (+/-0,2) Tapa: 1,0 (+/-0,2)	39,5 (+/-0,6)	22,2 (+/-0,6)	2000 (+/-3,0)	663,3 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos

Fecha de Emisión: 2020-05-07

Fecha de Vencimiento: 2026-05-07

Versión 2; 2023-03-03

Página 2 de 4



This document cancels and supersedes the last version of this certificate number issued by SGS Colombia S.A.S.

Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to: sgs.servicioalcliente@sgs.com, via phone No. (+57) 601608282 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of clients' instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023



SGS COLOMBIA S.A.S.
C&P-F490101
ORDEN No. 4200_31408
CERTIFICADO No. CRS15788
ORDEN CERT. No. CO-CERT200500428-04
CERTIFICADO DE CONFORMIDAD DE PRODUCTO
Acme León Plásticos S.A.S.
Calle 27 No. 7A-01, Funza

Referencia	Material	Espesor (mm)	Dimensiones Externas - Ancho (mm)	Dimensiones Externas - Alto (mm)	Dimensiones Externas - Largo (mm)	Volumen (mm³)	Estándar De Ensayo	Marca
CANALETA 40X25 LISA CON Y SIN ADH	PVC	Base: 1,1 (+/-0,2) Tapa: 1,0 (+/-0,2)	39,5 (+/-0,8)	22,2 (+/-0,8)	2000 (+/- 3,0)	680,4 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 40X25 CLIP LISA	PVC	Base: 1,0 (+/-0,1) Tapa: 1,0 (+/-0,1)	40,5 (+/-0,5)	25,5 (+/-0,5)	2000 (+/- 3,0)	808,6 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 40X25 CLIP DIVISION	PVC	Base: 1,0 (+/-0,1) Tapa: 1,0 (+/-0,1)	40,5 (+/-0,5)	25,5 (+/-0,5)	2000 (+/- 3,0)	788,6 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 40X40 LISA	PVC	Base: 1,0 (+/-0,1) Tapa: 1,0 (+/-0,1)	40,0 (+/-0,5)	36,0 (+/-0,5)	2000 (+/- 3,0)	1179,0 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 60X40 DIVISION	PVC	Base: 1,4 (+/-0,3) Tapa: 1,2 (+/-0,2)	61,0 (+/-0,6)	41,5 (+/-0,6)	2000 (+/- 3,0)	2109 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 60X40 LISA	PVC	Base: 1,4 (+/-0,3) Tapa: 1,2 (+/-0,2)	61,0 (+/-0,6)	41,5 (+/-0,6)	2000 (+/- 3,0)	2144,3 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 60X40 CLIP LISA	PVC	Base: 1,3 (+/-0,1) Tapa: 1,15 (+/-0,1)	61,0 (+/-0,5)	40,9 (+/-0,5)	2000 (+/- 3,0)	2138,7 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 60X40 CLIP DIVISION	PVC	Base: 1,3 (+/-0,1) Tapa: 1,3 (+/-0,1)	61,0 (+/-0,5)	40,5 (+/-0,5)	2000 (+/- 3,0)	2005,1 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 54X14 PISO	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	51,4 (+/-0,5)	14,6 (+/-0,5)	2000 (+/- 3,0)	282,4 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 70X17 PISO	PVC	Base: 1,4 (+/-0,1) Tapa: 1,4 (+/-0,1)	66,8 (+/-0,5)	18,5 (+/-0,5)	2000 (+/- 3,0)	543,9 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 100X45	PVC	Base: 1,5 (+/-0,3) Tapa: 1,5 (+/-0,3)	101,5 (+/-0,6)	45,8 (+/-0,6)	2000 (+/- 3,0)	3995,1 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 25X25 RANURADA	PVC	Base: 0,9 (+/-0,1) Tapa: 0,7 (+/-0,1)	25,0 (+/-0,5)	24,0 (+/-0,5)	2000 (+/- 3,0)	480,0 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos

Fecha de Emisión: 2020-05-07
Fecha de Vencimiento: 2026-05-07
Versión 2; 2023-03-03

Página 3 de 4



This document cancels and supersedes the last version of this certificate number issued by SGS Colombia S.A.S.

Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to: cs.servicioalcliente@sgs.com. Via phone No. (+57) 60160822 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/terms-and-conditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of clients' instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023





ISO/IEC 17065:2012
10-CPR-009



SGS COLOMBIA S.A.S.
C&P-F490101
ORDEN No. 4200_31408
CERTIFICADO No. CRS15788
ORDEN CERT. No. CO-CERT200500428-04
CERTIFICADO DE CONFORMIDAD DE PRODUCTO
Acme León Plásticos S.A.S.
Calle 27 No. 7A-01, Funza

Referencia	Material	Espesor (mm)	Dimensiones Externas - Ancho (mm)	Dimensiones Externas - Alto (mm)	Dimensiones Externas - Largo (mm)	Volumen (mm³)	Estándar De Ensayo	Marca
CANALETA 25X40 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	30,0 (+/-0,5)	44,0 (+/-0,5)	2000 (+/-3,0)	1060,5 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 25X60 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	30,0 (+/-0,5)	64,0 (+/-0,5)	2000 (+/-3,0)	1600,7 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 40X25 RANURADA	PVC	Base: 1,0 (+/-0,1) Tapa: 1,0 (+/-0,1)	39,0 (+/-0,5)	24,3 (+/-0,5)	2000 (+/-3,0)	790,2 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 40X60 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	47,0 (+/-0,5)	59,0 (+/-0,5)	2000 (+/-3,0)	2417,5 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 60X40 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	65,5 (+/-0,5)	42,0 (+/-0,5)	2000 (+/-3,0)	2391,0 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 60X60 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	65,5 (+/-0,5)	62,0 (+/-0,5)	2000 (+/-3,0)	3640,0 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 85X60 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	84,0 (+/-0,5)	60,0 (+/-0,5)	2000 (+/-3,0)	4510,4 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
CANALETA 120X60 RANURADA	PVC	Base: 1,5 (+/-0,1) Tapa: 1,5 (+/-0,1)	119,0 (+/-0,5)	60,0 (+/-0,5)	2000 (+/-3,0)	6461,3 (+/-1,0)	IEC 61084-1:2017	Acme León Plásticos
ACCESORIOS PARA CANALETA	-	-	-	-	-	-	-	Acme León Plásticos

FIN DEL DOCUMENTO

Fecha de Emisión: 2020-05-07
Fecha de Vencimiento: 2026-05-07
Versión 2; 2023-03-03

Página 4 de 4



This document cancels and supersedes the last version of this certificate number issued by SGS Colombia S.A.S.

Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to: cs.servicioalcliente@sgs.com. Via phone No. (+57) 601608282 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/terms-and-conditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of clients' instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023

